



# Ultrasonic level measuring device

- For level measurement up to 8 m
- 4...20 mA/HART 2 wires
- Suitable for solids
- ATEX certification



## Product variants described in the data sheet may differ from the product presentation and description.

### Can be combined with

	Type 8611 eCONTROL - Universal controller
	Type 8644 Remote Process Actu- ation Control System AirLINE
<b>T</b> el	Type 8793 ► Digital electropneumat- ic Process Controller SideControl
	Type 8802 ELEMENT continuous control valve systems - overview

## Type description

The type 8177 is a non-contact ultrasonic level measuring device, designed for continuous level measurement in open or closed vessels.

The unit is suitable for liquids, but also for solids, in virtually all industries, particularly in water and waste water management.



# **Table of contents**

1.	Ger	neral technical data 3			
2.	Арр	provals 5			
	2.1. ATEX-Certification				
3.	Mat	terials 5			
	3.1.	Chemical Resistance Chart – Bürkert resistApp5			
4.	Dim	iensions 6			
5.	Per	formance specifications 7			
	5.1.	Measurement deviation diagram7			
6.	Pro	duct operation 7			
	6.1. 6.2.	Measuring principle			
7.	Ord	ering information 8			
	7.1. 7.2. 7.3. 7.4.	Bürkert eShop – Easy ordering and quick delivery			



# 1. General technical data

Product properties					
Material					
	s are compatible with the fluid you are using. chapter "3.1. Chemical Resistance Chart – Bürkert resistApp" on page 5.				
Non wetted parts					
Housing	PBT, stainless steel 316L (1.4404)				
Cover	PC transparent				
Seal between housing and cover	EPDM				
Cable gland	PA				
Blind plug	PA				
Ground terminal	Stainless steel 316Ti/316L (1.4571/1.4435)				
Wetted parts					
Process connection	PVDF				
Transducer	PVDF				
Process seal	EPDM				
Dimensions	Detailed information can be found in chapter "4. Dimensions" on page 6.				
Weights	1.84 kg (depending on process connection and housing)				
Measuring variable	Distance between lower edge of the transducer and product surface. Detailed information can be found in chapters <b>"5.1. Measurement deviation diagram" on page 7</b> .				
Measuring range	• 0.48 m (for liquids)				
	• 0.43.5 m (for solids)				
Beam angle <sup>1.)</sup>	11°				
Damping (63 % of the input value)	0999 s, adjustable				
Adjustment time <sup>2.)</sup>	>3 s (dependent on the parameter adjustment)				
Product accessories					
Display	LCD in full dot matrix. Detailed information can be found in chapter "7.4. Ordering chart accessories" on page 8.				
Performance data					
Blocking distance	0.4 m				
Measurement deviation	±4 mm (measuring distance > 0.2 m) Detailed information can be found in chapter "5.1. Measurement deviation diagram" on page 7.				
Measuring range resolution	Max. 1 mm				
Measuring frequency	55 kHz				
Measuring cycle time	>2 s (dependent on the parameter adjustment)				
Temperature coefficient	0.06 %/10K (average temperature coefficient of the zero signal - temperature error)				
Vibration resistance	Mechanical vibrations with 4 g and 5100 Hz (tested according to the guidelines of Ger- man Lloyd, GL directive 2)				
Electrical data					
Operating voltage (U <sub>n</sub> )	Without display/configuration module:				
	– 1435 V DC				
	<ul> <li>1430 V DC (Ex ia instrument)</li> </ul>				
	With display/configuration module:				
	– 2035 V DC				
Power source (not supplied)	<ul> <li>2030 V DC (Ex ia instrument)</li> <li>Limited power source according to UL/EN 60950-1 standards or limited energy circuit according to UL/EN 61010-1 §9.4</li> </ul>				
Output signal	420 mA/HART				
Signal resolution	1.6 μΑ				
Load resistor	$(U_{n} - U_{min})/0.022 \text{ A}$				
Fault signal	Current output: mA value unchanged, 20.5 mA, 22 mA or <3.6 mA (adjustable)				
Max. output current	22 mA				
Residual ripple (at DC)	• <100 Hz: Uss <1 V				
	• 100 Hz10 kHz: Uss <10 mV				



Voltage supply cable	Cable diameter: 59 mm			
	Wire cross-section (spring-loaded terminals):			
	<ul> <li>massive wire, stranded wire: 0.22.5 mm<sup>2</sup> (AWG 2414)</li> </ul>			
	- stranded wire with end sleeve: 0.21.5 mm <sup>2</sup> (AWG 2416)			
Medium data				
Process temperature	-40 °C+80 °C (-40 °F176 °F)			
Process pressure Vessel pressure: -0.22 bar (-2.929.02 PSI/-20200 kPa)				
Process/Port connection & commun	nication			
Process connection	Thread G 2"			
	Thread NPT 2"			
Electrical connection	Cable glands M20 x 1.5			
Approvals and Certificates				
Standards				
Degree of protection according to IEC/EN 60529	IP66/IP67 with M20 x 1.5 gland mounted and tightened			
Overvoltage category according to IEC 61010-1	Category III			
Protection class according to IEC 61010-1				
Directives				
CE directives	The applied standards, which verify conformity with the EU Directives, can be found on the EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable			
NAMUR recommendations	<ul> <li>NE21 – Electromagnetic compatibility of equipment</li> </ul>			
	<ul> <li>NE43 – Signal level for fault information from measuring transducers</li> </ul>			
	<ul> <li>NE53 - Compatibility of field devices and display/adjustment components</li> </ul>			
Approvals				
ATEX	EN 50014, EN 50020, EN 50284 Detailed information can be found in chapter "2.1. ATEX-Certification" on page 5.			
Environment and installation				
Ambient temperature	Operation and storage:			
	<ul> <li>-40 °C+80 °C (-40 °F+176 °F)</li> </ul>			
	<ul> <li>Restricted to -20 °C+70 °C (-4 °F+158 °F) if equipped with display/configuration module</li> </ul>			
Relative air humidity				
Relative air humidity	module			
Relative air humidity Height above sea level	<ul><li>Module</li><li>Operation: max. 75 %, without condensation</li></ul>			
	<ul> <li>module</li> <li>Operation: max. 75 %, without condensation</li> <li>Storage: 2085 %, without condensation</li> </ul>			

1.) At -3 dB

2.) Time to output the correct level (with max. 10 % deviation) after a sudden level change



## 2. Approvals

## 2.1. ATEX-Certification

#### Note:

Devices with Ex certification have different technical data, see Supplement ATEX Type 8177 > under user manual.

Certificate	Description
$\overline{c}$	EU-Type Examination Certificate Number: PTB 07 ATEX 2003X
$\langle c x \rangle$	ATEX II 1/2G resp. II 2G EEx ia IIC T6
	Measures to comply with ATEX requirements: refer to the <b>Supplement ATEX Type 8177</b> Inder user manual. The Ex. certification is only valid if the Bürkert device is used as described in the supplement ATEX. If unauthorized changes are made to the device, the Ex. certification becomes invalid.

# 3. Materials

## 3.1. Chemical Resistance Chart – Bürkert resistApp



#### Bürkert resistApp – Chemical Resistance Chart

You want to ensure the reliability and durability of the materials in your individual application case? Verify your combination of media and materials on our website or in our resistApp.

Start Chemical Resistance Check



# 4. Dimensions

#### Note:

Dimensions in mm







# 6. Product operation

#### 6.1. Measuring principle

The transducer of the ultrasonic measuring device emits short ultrasonic pulses, at 55 kHz to the measured product. These pulses are reflected by the medium surface and received by the transducer as echoes. The running time of the ultrasonic pulses from emission to reception is proportional to the distance and hence to the level. An integrated temperature sensor detects the temperature in the vessel and compensates the influence of temperature on the signal running time. The determined level is converted into an output signal and transmitted as a measured value.

## 6.2. Product operation notes

#### Set up with display/configuration module

The measuring device is adjusted with the display/configuration module. The entered parameters are generally saved in the measuring device, Type 8177. Optionally, parameters may also be uploaded and downloaded with the display/configuration module.

Display/configuration module	Description
	The display/configuration module can be inserted into the measuring device and removed again at any time. It is not necessary to interrupt the power supply. The measuring device is adjusted via the four keys of the display/configuration module.



# 7. Ordering information

## 7.1. Bürkert eShop - Easy ordering and quick delivery



#### 7.2. Bürkert product filter



#### 7.3. Ordering chart

Description	Operating voltage	Output	Electrical connection	Article no. with display/ configuration module	Article no. without display/ configuration module
G 2" mounting thread	1435 V DC	420 mA/HART (2 wires)	Cable gland M20 x 1.5	558224 ቛ	559243 🐖
NPT 2" mounting thread				558225 📜	559244 📜
Ex version – ATEX approval G 2" mounting thread				558226 🛒	559245 🛒

#### 7.4. Ordering chart accessories

Description	Article no.
Set with 2 reductions M20 x 1.5/NPT $\frac{1}{2}$ + 2 neoprene flat seals for cable gland + 2 screw-plugs M20 x 1.5	551782 🛒
Set with a display/configuration module, a transparent cover and a seal ring	559279 🛒
Set with a transparent cover and a seal ring	561006 🛒

# Bürkert – Close to You

For up-to-date addresses please visit us at www.burkert.com



Credits, © and concept: Christian Bürkert GmbH & Co. KG | Photographs: Marc Eggimann Fotografie - 4051 Basel | Scanner GmbH - Werbeagentur Künzelsau - 74653 Künzelsau